





# **Manual - SmartShunt IP65**

Rev 01 09/2022

# **Table of Contents**

1. Sa	ty precautions	
	1.1. Battery safety warnings	4
	1.2. Transport and storage	
2. Int	duction	
	2.1. Battery monitor	
	2.2. Why should I monitor my battery?	
	2.3. Sizing	
	2.4. The VictronConnect app	
	2.5. Accessories	
3. Ins	ıllation	4
	3.1. Mounting the SmartShunt	
	3.2. Connections overview	
	3.3. Basic electrical connections	4
	3.4. Auxiliary electrical connections	<u>5</u>
	3.4.1. Auxiliary connection for monitoring the voltage of	a second battery5
	3.4.2. Auxiliary connection midpoint battery bank monit	
	3.4.3. Auxiliary connection for temperature monitoring	
	3.5. GX device connection	
	3.6. Wiring for use as DC meter	6
4.0-	T41	,
4. Co	figuration	c
	4.1. How to change settings	
	4.2. The VictronConnect app	
	··	
	4.3. Update firmware	
	4.4. Make essential settings	
	4.4.1. Set the battery capacity value	
	4.4.2. Set charged voltage value	g
	4.4.3. Set state of charge	g
	4.4.4. Set the auxiliary input function	
	4.5. Make Lithium settings (if needed)	
	4.6. Configure for use as DC meter	
	+.0. Configure for use as DC meter	
5. Or	ration	
J. J.		
	5.1. How does the battery monitor work?	12
	5.2. Readout overview	12
	5.3. LED status codes	
	5.4. Trends	
	5.5. History	
	5.5.1. Access history via VictronConnect	
	5.5.2. History data	
	5.6. Alarms	
	5.7. Synchronising the battery monitor	
	5.7.1. Automatic synchronisation	15
	5.7.2. Manual synchronisation	
	5.8. Operation as a DC meter	
	5.0. Operation as a Bo meter	
6. Int	facing	
	· ·	
	3.1. VictronConnect via USB	
	6.2. Connecting to a GX device and the VRM portal	17
	6.3. Connecting to a VE.Smart network	
	6.4. Custom integration	
7. All	eatures and settings	
	-	
	7.1. Battery settings	
	7.1.1. Battery capacity	
	7.1.2. Charged voltage	20
	7.1.3. Discharge floor	
	7.1.4. Tail current	



	kert exponent	
	rge efficiency factor	
	rent threshold	
	e-to-go averaging period	
	ttery starts synchronised	
	tte of charge	
	nchronise SoC to 100%	
	ro current calibration	
	S	
	alarm setting voltage alarm	
	n voltage alarm	
•	starter voltage alarm	
	n starter voltage alarm	
•	point deviation alarm	
	n temperature alarm	
	temperature alarm	
	is settings	
	itor Mode	
	input	
7.3.3. Tem	perature coefficient	. 25
	unit setting	
	ngs	
7.5.1. Res	et to defaults	. 25
7.5.2. Cust	tom name	. 26
	ware	
	nging PIN code	
	abling and re-enabling Bluetooth	
	al number	
	ing and sharing settings	
	/	
X Reset PIN co		. 27
	d Peukert exponent	. 28
ery capacity and		
ery capacity and	Deukert exponent	. 30
ery capacity and oint voltage mo	d Peukert exponent	. <b>30</b>
ry capacity and oint voltage mo .1. Battery bank 9.1.1. Con	onitoring	. <b>30</b>
ry capacity and pint voltage mo .1. Battery bank 9.1.1. Con 9.1.2. Con	and midpoint wiring diagrams necting and monitoring midpoint in a 24V battery bank	. 30 . 30 . 30
oint voltage mo 1. Battery bank 9.1.1. Con 9.1.2. Con 2. Midpoint dev	and midpoint wiring diagrams necting and monitoring midpoint in a 24V battery bank necting and monitoring midpoint in a 48V battery bank	. 30 . 30 . 31 . 31
oint voltage mo 9.1. Battery bank 9.1.1. Con 9.1.2. Con 9.2. Midpoint dev 9.3. Setting the al	and midpoint wiring diagrams necting and monitoring midpoint in a 24V battery bank necting and monitoring midpoint in a 48V battery bank iation calculation	. 30 . 30 . 31 . 31
oint voltage mo 0.1. Battery bank 9.1.1. Con 9.1.2. Con 0.2. Midpoint dev 0.3. Setting the al 0.4. Alarm delay	and midpoint wiring diagrams necting and monitoring midpoint in a 24V battery bank necting and monitoring midpoint in a 48V battery bank iation calculation	. 30 . 30 . 31 . 31 . 31
pint voltage mo 1. Battery bank 9.1.1. Con 9.1.2. Con 2. Midpoint dev 3. Setting the al 4. Alarm delay 5. What to do in	and midpoint wiring diagrams necting and monitoring midpoint in a 24V battery bank necting and monitoring midpoint in a 48V battery bank iation calculation	. 30 . 30 . 31 . 31 . 32
point voltage mo 9.1. Battery bank 9.1.1. Con 9.1.2. Con 9.2. Midpoint dev 9.3. Setting the al 9.4. Alarm delay 9.5. What to do in 9.6. What to do in	and midpoint wiring diagrams necting and monitoring midpoint in a 24V battery bank necting and monitoring midpoint in a 48V battery bank iation calculation larm level	. 30 . 30 . 31 . 31 . 32 . 32
point voltage mo 9.1. Battery bank 9.1.1. Con 9.1.2. Con 9.2. Midpoint dev 9.3. Setting the al 9.4. Alarm delay 9.5. What to do in 9.6. What to do in 9.7. The Battery E	and midpoint wiring diagrams necting and monitoring midpoint in a 24V battery bank necting and monitoring midpoint in a 48V battery bank iation calculation larm level n case of an alarm during charging n case of an alarm during discharging Balancer	. 30 . 30 . 31 . 31 . 32 . 32 . 33
oint voltage mo 1.1. Battery bank 9.1.1. Con 9.1.2. Con 1.2. Midpoint dev 1.3. Setting the al 1.4. Alarm delay 1.5. What to do in 1.7. The Battery E	and midpoint wiring diagrams necting and monitoring midpoint in a 24V battery bank necting and monitoring midpoint in a 48V battery bank iation calculation larm level n case of an alarm during charging n case of an alarm during discharging Balancer	. 30 . 30 . 31 . 31 . 32 . 32 . 32
oint voltage mo 9.1. Battery bank 9.1.1. Con 9.1.2. Con 9.2. Midpoint dev 9.3. Setting the al 9.4. Alarm delay 9.5. What to do in 9.6. What to do in 9.7. The Battery E	and midpoint wiring diagrams necting and monitoring midpoint in a 24V battery bank necting and monitoring midpoint in a 48V battery bank iation calculation larm level n case of an alarm during charging n case of an alarm during discharging Balancer	. 30 . 30 . 31 . 31 . 32 . 32 . 33
ry capacity and oint voltage mo .1. Battery bank 9.1.1. Con 9.1.2. Con .2. Midpoint dev .3. Setting the al .4. Alarm delay .5. What to do ir .6. What to do ir .7. The Battery E  ibleshooting 0.1. Functionalit 10.1.1. Un	and midpoint wiring diagrams necting and monitoring midpoint in a 24V battery bank necting and monitoring midpoint in a 48V battery bank iation calculation larm level n case of an alarm during charging n case of an alarm during discharging Balancer  y issues it is dead	. 30 . 30 . 31 . 31 . 32 . 32 . 33 . 34 . 34
oint voltage mo  1. Battery bank 9.1.1. Con 9.1.2. Con 2. Midpoint dev 3. Setting the al 4. Alarm delay 5. What to do in 6. What to do in 7. The Battery E  bleshooting 0.1. Functionalit 10.1.1. Un 10.1.2. Au:	and midpoint wiring diagrams necting and monitoring midpoint in a 24V battery bank necting and monitoring midpoint in a 48V battery bank iation calculation larm level n case of an alarm during charging n case of an alarm during discharging Balancer	. 30 . 30 . 31 . 31 . 32 . 32 . 33 . 34 . 34
ry capacity and oint voltage mo 1. Battery bank 9.1.1. Con 9.1.2. Con 2. Midpoint dev 3. Setting the al 4. Alarm delay 5. What to do in 7. The Battery B bleshooting 0.1. Functionalit 10.1.1. Un 10.1.2. Au 10.1.3. Un	and midpoint wiring diagrams necting and monitoring midpoint in a 24V battery bank necting and monitoring midpoint in a 48V battery bank iation calculation larm level n case of an alarm during charging n case of an alarm during discharging Salancer  y issues it is dead xiliary port not working	. 30 . 30 . 31 . 31 . 32 . 32 . 33 . 34 . 34 . 34
ry capacity and bint voltage mo 1. Battery bank 9.1.1. Con 9.1.2. Con 2. Midpoint dev 3. Setting the al 4. Alarm delay 5. What to do in 6. What to do in 7. The Battery B bleshooting 0.1. Functionalit 10.1.1. Un 10.1.2. Au 10.1.3. Un 0.2. Connection	and midpoint wiring diagrams necting and monitoring midpoint in a 24V battery bank necting and monitoring midpoint in a 48V battery bank iation calculation larm level  n case of an alarm during charging n case of an alarm during discharging Salancer  y issues it is dead xiliary port not working able to change VictronConnect settings	. 30 . 30 . 31 . 31 . 32 . 32 . 33 . 34 . 34 . 34
oint voltage mo .1. Battery bank 9.1.1. Con 9.1.2. Con .2. Midpoint dev .3. Setting the al .4. Alarm delay .5. What to do ir .6. What to do ir .7. The Battery E  ubleshooting 0.1. Functionalit 10.1.1. Un 10.1.2. Au 10.1.3. Un 0.2. Connection 10.2.1. Ca	and midpoint wiring diagrams necting and monitoring midpoint in a 24V battery bank necting and monitoring midpoint in a 48V battery bank iation calculation larm level  n case of an alarm during charging n case of an alarm during discharging Salancer  y issues it is dead xiliary port not working able to change VictronConnect settings issues	. 30 . 30 . 31 . 31 . 32 . 32 . 33 . 34 . 34 . 34 . 34 . 34
ry capacity and oint voltage mo .1. Battery bank 9.1.1. Con 9.1.2. Con .2. Midpoint dev .3. Setting the al .4. Alarm delay .5. What to do ir .6. What to do ir .7. The Battery E  ibleshooting 0.1. Functionalit 10.1.1. Un 10.1.2. Au 10.1.3. Un 0.2. Connection 10.2.1. Ca 10.2.2. PIN	In Peukert exponent  Indiving  and midpoint wiring diagrams necting and monitoring midpoint in a 24V battery bank necting and monitoring midpoint in a 48V battery bank iation calculation larm level  In case of an alarm during charging In case of an alarm during discharging Isalancer  It is dead	. 30 . 30 . 31 . 31 . 32 . 32 . 33 . 34 . 34 . 34 . 34 . 34 . 34 . 34
oint voltage mode.  1. Battery bank. 9.1.1. Con. 9.1.2. Con. 2. Midpoint dev. 3. Setting the al. 4. Alarm delay. 5. What to do in. 6. What to do in. 7. The Battery E.  bleshooting 0.1. Functionalit. 10.1.1. Un. 10.1.2. Au 10.1.3. Un. 0.2. Connection. 10.2.1. Ca 10.2.2. PIN. 0.3. Incorrect residents.	A Peukert exponent  Individual Peukert expone	30 30 31 31 31 32 32 32 32 34 34 34 34 34 34 34 34 34 34 34 34 34
ry capacity and oint voltage mo .1. Battery bank 9.1.1. Con 9.1.2. Con .2. Midpoint dev .3. Setting the al .4. Alarm delay .5. What to do in .6. What to do in .7. The Battery E ubleshooting 0.1. Functionalit 10.1.1. Un 10.1.2. Au 10.1.3. Un 0.2. Connection 10.2.1. Ca 10.2.2. PIN 0.3. Incorrect rec 10.3.1. Ch	In Peukert exponent  In Peukert exponent  In Iteration of the period of	30 30 30 30 31 31 32 32 32 32 33 34 34 34 34 35 35 35 35 35 35 35
ry capacity and oint voltage mo 1. Battery bank 9.1.1. Con 9.1.2. Con 2. Midpoint dev 3. Setting the al 4. Alarm delay 5. What to do in 7. The Battery E  oldeshooting 0.1. Functionalit 10.1.1. Un 10.1.2. Au 10.1.3. Un 0.2. Connection 10.2.1. Ca 10.2.2. PIN 0.3. Incorrect rea 10.3.1. Ch 10.3.2. Inc	A Peukert exponent  Individual point wiring diagrams Inecting and monitoring midpoint in a 24V battery bank Inecting and monitoring midpoint in a 48V battery bank Inecting and monitoring midpoint in a 48V battery bank Initiation calculation In case of an alarm during charging In case of an alarm during discharging In case of an alarm during discharging It is dead It is de	30 30 30 30 30 30 30 30 30 30 30 30 30 3
ry capacity and oint voltage mo .1. Battery bank 9.1.1. Con 9.1.2. Con .2. Midpoint dev .3. Setting the al .4. Alarm delay .5. What to do in .6. What to do in .7. The Battery E  ubleshooting 0.1. Functionalit 10.1.1. Un 10.1.2. Au 10.1.3. Un 0.2. Connection 10.2.1. Ca 10.2.2. PIN 0.3. Incorrect re 10.3.1. Ch 10.3.2. Inc 10.3.3. The	A Peukert exponent  Donitoring  and midpoint wiring diagrams necting and monitoring midpoint in a 24V battery bank necting and monitoring midpoint in a 48V battery bank iation calculation larm level  In case of an alarm during charging In case of an alarm during discharging Balancer   y issues it is dead xiliary port not working able to change VictronConnect settings issues nnot connect via Bluetooth N code lost adings arge and discharge current are inverted complete current reading	. 30 . 30 . 31 . 31 . 32 . 32 . 32 . 34 . 34 . 34 . 34 . 34 . 34 . 34 . 35 . 35 . 35 . 35 . 35 . 35 . 35 . 35
ry capacity and oint voltage mo 1. Battery bank 9.1.1. Con 9.1.2. Con 2. Midpoint dev 3. Setting the al 4. Alarm delay 5. What to do in 6. What to do in 7. The Battery E  oldeshooting 0.1. Functionalit 10.1.1. Un 10.1.2. Au 10.1.3. Un 0.2. Connection 10.2.1. Ca 10.2.2. PIN 0.3. Incorrect rea 10.3.1. Ch 10.3.2. Inc 10.3.3. The 10.3.4. Inc	Interior exponent  Indicate the property of th	30 30 30 31 31 32 32 32 33 34 34 34 34 35 35 35 35 35 35 35 35 35 35 35 35 35
oint voltage mo  1.1. Battery bank 9.1.1. Con 9.1.2. Con 9.1.2. Con 9.3. Setting the al 9.4. Alarm delay 1.5. What to do in 1.6. What to do in 1.7. The Battery E  ubleshooting  0.1. Functionalit 10.1.1. Un 10.1.2. Au: 10.1.3. Un 0.2. Connection 10.2.1. Ca 10.2.2. PIN 0.3. Incorrect re: 10.3.1. Ch 10.3.2. Inc 10.3.3. The 10.3.4. Inc 10.3.5. Sta	Interior exponent  Individual states of the state of charge and discharge current reading succorrect state of charge read	. 30 . 30 . 31 . 31 . 32 . 32 . 32 . 34 . 34 . 34 . 34 . 35 . 35 . 35 . 35 . 35 . 35 . 35 . 35
oint voltage mo  1.1. Battery bank 9.1.1. Con 9.1.2. Con 9.1.2. Con 9.3. Setting the al 9.4. Alarm delay 9.5. What to do in 9.7. The Battery B  ubleshooting 0.1. Functionalit 10.1.1. Un 10.1.2. Au: 10.1.3. Un 0.2. Connection 10.2.1. Ca 10.2.2. PIN 0.3. Incorrect re: 10.3.1. Ch 10.3.2. Inc 10.3.3. The 10.3.4. Inc 10.3.5. Sta 10.3.6. Sta 10.3.7. Sta	and midpoint wiring diagrams necting and monitoring midpoint in a 24V battery bank necting and monitoring midpoint in a 48V battery bank necting and monitoring midpoint in a 48V battery bank nation calculation larm level  n case of an alarm during charging n case of an alarm during discharging Balancer  y issues it is dead xililiary port not working able to change VictronConnect settings issues nnot connect via Bluetooth N code lost addings arge and discharge current are inverted complete current reading ere is a current reading while no current flows correct state of charge reading atte of charge is missing atte of charge always shows 100% atte of charge always shows 100% atte of charge always shows 100%	30 30 30 31 31 31 32 32 32 32 32 34 34 34 34 35 35 35 35 35 36 36 36 36 36 36 36 36 36 36 36 36 36
oint voltage mo  2.1. Battery bank 9.1.1. Con 9.1.2. Con 9.2. Midpoint dev 9.3. Setting the al 9.4. Alarm delay 9.5. What to do in 9.7. The Battery E  ubleshooting 10.1. Functionalit 10.1.1. Un 10.1.2. Au: 10.1.3. Un 10.2. Connection 10.2.1. Ca 10.2.2. PIN 10.3. Incorrect re: 10.3.1. Ch 10.3.2. Inc 10.3.3. The 10.3.4. Inc 10.3.5. Sta 10.3.6. Sta 10.3.7. Sta 10.3.8. Sta	and midpoint wiring diagrams necting and monitoring midpoint in a 24V battery bank necting and monitoring midpoint in a 48V battery bank necting and monitoring midpoint in a 48V battery bank necting and monitoring midpoint in a 48V battery bank necting and monitoring midpoint in a 48V battery bank necting and monitoring midpoint in a 48V battery bank necting and during charging nease of an alarm during charging nease of an alarm during discharging nease of an alarm during charging nease of an	30 30 30 31 31 31 32 32 32 32 34 34 34 34 35 35 35 35 35 36 36 36 36 36 37
oint voltage mo 1.1. Battery bank 9.1.1. Con 9.1.2. Con 1.2. Midpoint dev 1.3. Setting the al 1.4. Alarm delay 1.5. What to do in 1.6. What to do in 1.7. The Battery E 1.8. Libeshooting 1.9. Libeshooting 1.1. Un 10.1.2. Au: 10.1.3. Un 10.2.1. Ca 10.2.2. PIN 10.3.1. Ch 10.3.2. Inc 10.3.3. The 10.3.4. Inc 10.3.5. Sta 10.3.6. Sta 10.3.7. Sta 10.3.8. Sta 10.3.9. Inc	and midpoint wiring diagrams necting and monitoring midpoint in a 24V battery bank necting and monitoring midpoint in a 48V battery bank necting and monitoring midpoint in a 48V battery bank nation calculation larm level  n case of an alarm during charging n case of an alarm during discharging Balancer  y issues it is dead xiliary port not working able to change VictronConnect settings issues nnot connect via Bluetooth N code lost addings arge and discharge current are inverted complete current reading ere is a current reading while no current flows correct state of charge reading ste of charge does not reach 100% ste of charge does not reach 100% ste of charge does not increase fast enough or too fast when charging correct battery voltage reading	30 30 30 31 31 31 32 32 32 32 34 34 34 35 35 35 35 36 36 36 36 36 37 37 37
oint voltage mo  1. Battery bank 9.1.1. Con 9.1.2. Con 2. Midpoint dev 3. Setting the al 4. Alarm delay 5. What to do in 6. What to do in 7. The Battery E  ubleshooting  0.1. Functionalit 10.1.1. Un 10.1.2. Au: 10.1.3. Un 0.2. Connection 10.2.1. Ca 10.2.2. PIN 0.3. Incorrect re: 10.3.1. Ch 10.3.2. Inc 10.3.3. The 10.3.4. Inc 10.3.5. Sta 10.3.6. Sta 10.3.7. Sta 10.3.8. Sta 10.3.9. Inc 10.3.10. In	and midpoint wiring diagrams necting and monitoring midpoint in a 24V battery bank necting and monitoring midpoint in a 48V battery bank necting and monitoring midpoint in a 48V battery bank necting and monitoring midpoint in a 48V battery bank necting and monitoring midpoint in a 48V battery bank necting and monitoring midpoint in a 48V battery bank necting and during charging nease of an alarm during charging nease of an alarm during discharging nease of an alarm during charging nease of an	30 30 30 31 31 31 32 32 32 32 32 34 34 34 35 35 35 35 36 36 36 36 37 37 37 37 37



# Manual - SmartShunt IP65

11. Technical data	38
11.1. Technical data	38
12. Appendix	40
12.1. Dimensions SmartShunt IP65 500A	40
12.2. Dimensions SmartShunt IP65 1000A	41
12.2. Dimensions SmartSmart in 05 1000A	

# 1. Safety precautions

# 1.1. Battery safety warnings



Working in the vicinity of a lead acid battery is dangerous. Batteries can generate explosive gases during operation. Never smoke or allow a spark or flame in the vicinity of a battery. Provide sufficient ventilation around the battery.

Wear eye and clothing protection. Avoid touching eyes while working near batteries. Wash your hands when done.

If battery acid contacts skin or clothing, wash them immediately with soap and water. If acid enters an eye, immediately flood the eye with running cold water for at least 15 minutes and get medical attention immediately.

Be careful when using metal tools in the vicinity of batteries. Dropping a metal tool onto a battery might cause a short circuit and possibly an explosion.

Remove personal metal items such as rings, bracelets, necklaces, and watches when working with a battery. A battery can produce a short circuit current high enough to melt objects such as rings, causing severe burns.

# 1.2. Transport and storage



Store this product in a dry environment.

Store this product in temperatures between -40°C and +60°C.

# 2. Introduction

# 2.1. Battery monitor

The SmartShunt IP65 is a battery monitor. It measures battery voltage and current. Based on these measurements, the battery state of charge and time to go is calculated. It also keeps track of historical data, such as deepest discharge, average discharge and number of charge/discharge cycles.

The battery monitor can connect via Bluetooth to the VictronConnect app. The VictronConnect app is used to read out all monitored battery parameters or to change settings.

The battery monitor can be connected to a GX device, such as the Cerbo GX or the ColorControl GX. When connected, the battery can be monitored locally or remotely, via the VRM portal.

The battery monitor has an auxiliary input that can be used to monitor the voltage of a second battery or to monitor the midpoint of a battery bank. The auxiliary input can also be used for battery temperature monitoring together with the optional Temperature sensor for BMV.

The battery monitor can provide real time battery data in a VE.Smart network. It provides battery voltage and battery current information to the VE.Smart network for use by Victron solar chargers and select Victron AC chargers.

# 2.2. Why should I monitor my battery?

Batteries are used in a wide variety of applications, mostly to store energy for later use. But how much energy is stored in the battery? No one can tell by just looking at it. The service life of batteries depends on many factors. Battery life may be shortened by under-charging, over-charging, excessively deep discharges, excessive charge or discharge currents, and by high ambient temperature. Monitoring the battery with a battery monitor will give important feedback to the user so that remedial measures can be taken when necessary. Doing this will extend battery life and the battery monitor will quickly pay for itself.

# 2.3. Sizing

The SmartShunt IP65 is available in 3 sizes being: 500A, 1000A and 2000A.



SmartShunt IP65 500A, SmartShunt IP65 1000A and SmartShunt IP65 2000A

### 2.4. The VictronConnect app

The VictronConnect app is essential to set up and to monitor the battery monitor.

The app can connect to the battery monitor via:

- · Bluetooth.
- USB, via the optional VE.Direct to USB interface.

The app is available for the following platforms:

- Android
- · Apple iOS (Note that USB is not supported, it is only possible to connect via Bluetooth)
- MacOs
- · Windows (Note that Bluetooth is not supported, it is only possible to connect via USB).

The VictronConnect app can be downloaded from app stores or from the VictronConnect product page or scan below QR code.





# 2.5. Accessories

These optional parts might be needed depending on your setup:


- Temperature sensor for BMV to measure the battery temperature.
- GX device for system and/or remote monitoring.
- VE.Direct cable to connect the battery monitor to a GX device.
- VE.Direct to USB interface to connect to the battery monitor via USB to a GX device or to the VictronConnect app.

# 3. Installation

# 3.1. Mounting the SmartShunt


The SmartShunt has two 5.5 mm holes for mounting purposes located in the base of the SmartShunt. The holes can be used to screw or bolt the SmartShunt onto a hard surface (screws are not included).

For the exact location of the mounting holes see the dimension drawing in the appendix of this manual.



Top view SmartShunt IP65 indicating mounting holes and side view SmartShunt indicating mounting method.

#### 3.2. Connections overview



#	SmartShunt IP65 connection	Terminal type
Α	LOAD MINUS	M10 bolt
В	BATTERY MINUS	M10 bolt
С	VE.Direct (black wire)	VE.Direct socket
D	VBatt+ (red wire with fuse)	M10 ring terminal
E	Aux (grey wire with fuse)	M10 ring terminal

# 3.3. Basic electrical connections


Connection procedure:

- Connect the negative battery terminal to the M10 bolt on the BATTERY MINUS side of the shunt.
   Note that there should be no other connections on this side of the shunt or on the negative battery terminal. Any loads or chargers connected here will be excluded from the battery state of charge calculation.
- 2. Connect the negative of the electrical system to the M10 bolt on the LOAD MINUS side of the shunt. Make sure that the negative of all DC loads, inverters, battery chargers, solar chargers and other charge sources are connected "after" the shunt.
- 3. Connect the M10 terminal of the red cable with fuse to the positive terminal of the battery.

The battery monitor is now powered up.

The battery monitor needs to be configured to be fully operational, for that see chapter Configuration [8].

In case the battery monitor is going to be used to monitor a second battery, battery bank midpoint or battery temperature, see one of the next 3 paragraphs on how to do this and then go to chapter Configuration [8].



# 3.4. Auxiliary electrical connections

In addition to the comprehensive monitoring of the main battery bank, a second parameter can be monitored. This can be one of the following:

- · The voltage of a second battery, like a starter battery.
- · The midpoint deviation of the battery bank.
- · Battery temperature.


This chapter describes how to wire the Aux terminal for the three above options.

# 3.4.1. Auxiliary connection for monitoring the voltage of a second battery

The Aux terminal can be used to monitor the voltage of a second battery, such as a starter battery.

Connection procedure:

- 1. Verify that the negative pole of the second battery is connected to the LOAD MINUS side of the shunt.
- 2. Connect the M10 lug of the grey "Aux" cable to the positive terminal of the second battery.




# 3.4.2. Auxiliary connection midpoint battery bank monitoring

The Aux terminal can be used to monitor the midpoint voltage of a battery bank that consists of multiple batteries that are wired in series or series/parallel to create a 24V or 48V battery bank.

Connection procedure:

1. Connect the M10 lug of the grey "Aux" cable to the positive terminal of the midpoint.



For more information on midpoint monitoring and additional wiring diagrams see chapter Midpoint voltage monitoring [30].

#### 3.4.3. Auxiliary connection for temperature monitoring

The Aux terminal can be used to monitor the temperature of a battery via the (not included) Temperature sensor for BMV-712 Smart and BMV-702. This temperature sensor needs to be purchased separately. Be aware that this is a different temperature sensor than the temperature sensors that are included with Victron inverter/chargers and some battery chargers.




Temperature sensor for battery monitor




Note that the temperature sensor wires do not easily connect to the SmartShunt wires. You will have to make your own provision that the connection between the temperature sensor and the SmartShunt is made in a safe and electrical sound way.

Connection procedure:



### 3.5. GX device connection


Once connected, the GX device can be used to read out all monitored battery parameters. For more information see chapter Connecting to a GX device and the VRM portal [17].



# 3.6. Wiring for use as DC meter

When using the battery monitor as a DC meter, wire it to the device or circuit that needs to be monitored. Note that the battery monitor also needs to be configured as a DC monitor using the VictronConnect app before it will operate as a DC monitor. See the Configure for use as DC meter [11] chapter.

It is also possible to have a main battery monitor in the system together with a separate battery monitor that has been set up as a DC meter to monitor a specific device or circuit.



Wiring example of a system containing a main battery monitor, together with a battery monitor that has been set up as a DC meter and is monitoring a specific device or circuit.

#	Description	
Α	Specific DC device or DC circuit	
В	Battery monitor used as DC meter	
С	The rest of the DC circuit	
D	Battery monitor used as battery monitor	

# 4. Configuration

Once the electrical connections have been made and the battery monitor has been powered up it needs to be configured so it is suitable for the system it is used in.

This chapter describes how to configure the battery monitor by making the basic settings. For all settings and features see chapter All features and settings [20].

# 4.1. How to change settings

Configuration of the battery monitor is done by changing settings by using the VictronConnect app.

# 4.2. The VictronConnect app

The VictronConnect app can be used to change all settings and to update the firmware.

Ways to connect to the battery monitor:

- · Locally via built-in Bluetooth.
- · Remotely via VE.Direct, connected to a GX device, using the VRM portal. (See the VRM tab in the VictronConnect device list).


How to connect with the VictronConnect app to the battery monitor:

- · Open the VictronConnect app.
- · Ensure that the battery monitor is powered.
- · Look for the battery monitor to appear in the device list in the "Local" or the "VRM" tab.
- · Click on the battery monitor.
- Enter the default PIN code: 000000. After entering the default PIN code VictronConnect will ask you to change the PIN code. This is to prevent unauthorized connections in the future. It is recommended that you change the PIN code on first install. This can be done in the product info tab, see paragraph Changing PIN code [26].
- · When successfully connected the "Bluetooth" light stays on.

To view and/or change battery monitor settings navigate to the settings page by clicking on the cog icon 🌣 at the top right of the home screen.







VictronConnect settings



This manual only covers the battery monitor specific items. For more general information on the VictronConnect app, like how use it and where to download it or how to connect, see the VictronConnect app product page and manual.

# 4.3. Update firmware

On a new install, it is recommended to update the firmware of the battery monitor. If there is a newer firmware version available, the VictronConnect app will notify you of this as soon as a connection with the battery monitor is made.

To check if the firmware is up to date or to manually update firmware, connect to the battery monitor using the VictronConnect app and follow below steps:

- Navigate to the product settings by clicking the "coq" \* symbol in the top right hand of the product status screen.
- Click on the "3 dots" symbol in the top right hand of the settings screen.
- · Select "Product info" from the pop-up menu.
- The firmware version will be displayed. It is mentioned if this is the latest firmware version (or not). If a newer firmware version is available, an "UPDATE" button will be displayed.
- · To update the firmware, press the "UPDATE" button.

### 4.4. Make essential settings

The default settings of the battery monitor are tailored for lead acid batteries, like OPzV, OPzS, GEL or AGM batteries.

Most settings can stay at their factory default. But there are a few settings that need to be changed. These are:

- · Battery capacity.
- · Charged voltage.
- · The functionality of the auxiliary input (if used).
- · State of charge or start synchronised.



If lithium batteries (or batteries with a different chemistry) are used, some additional settings will have to be changed.

First make the essential settings as described in this paragraph and then refer to the next paragraph for the special lithium settings.



For more information about these and any of the other settings, see chapter All features and settings [20].

#### 4.4.1. Set the battery capacity value

In VictronConnect see: Settings > Battery.

The battery monitor is by default set to 200Ah. Change this value to match your battery capacity. For lead acid batteries we recommend to enter the 20 hour rate (C20).

#### 4.4.2. Set charged voltage value

In VictronConnect see: Settings > Battery > Charged voltage.

Although the battery monitor automatically detects the voltage, it is good practice to check if this setting is correctly set.

These are the recommended "Charged voltage" values:

Nominal battery voltage	Recommended charged voltage setting	
12 V	13.2 V	
24 V	26.4 V	
36 V	39.6 V	
48 V	52.8 V	

#### 4.4.3. Set state of charge

In VictronConnect see: Settings > Battery > Battery start synchronized.

When set to ON, the battery monitor will consider itself synchronized when powered up, resulting in a state of charge of 100%. If set to OFF, the battery monitor will consider itself un-synchronized when powered up, resulting in a state of charge that is unknown until the first actual synchronization.

<u>For VictronConnect only:</u> The initial state of charge value can also be manually set, by default this is 100%, and can be set to a different value if so desired. See: **Settings > Battery > State-of-charge**.

#### 4.4.4. Set the auxiliary input function

In VictronConnect see: Settings > Misc > Aux input.

This setting sets the function of the auxiliary input, being:

- · Starter battery Voltage monitoring of a second battery.
- · Midpoint Measuring the midpoint of a battery bank.
- Temperature Measuring battery temperature via optional temperature sensor.

# 4.5. Make Lithium settings (if needed)

LiFePO4 (Lithium Iron Phosphate or LFP) is the most used Li-ion battery chemistry. The factory defaults are in general also applicable to LFP batteries with exception of these settings:

- · Tail current.
- · Peukert exponent.
- · Charge efficiency.
- · Discharge floor.

#### Tail current

In VictronConnect see: Settings > Battery > Tail current.

Some lithium battery chargers stop charging when the current drops below a set threshold. The tail current must be set higher in this case.

#### Peukert exponent

In VictronConnect see: Settings > Battery > Peukert exponent.

When subjected to high discharge rates, lithium batteries perform much better than lead acid batteries. Set the Peukert exponent at 1.05, unless the battery supplier advises otherwise.

#### Charge efficiency

In VictronConnect see: Settings > Battery > Charge efficiency factor.

The charge efficiency of lithium batteries is much higher than that of lead acid batteries. We recommend setting the charge efficiency at 99%.

#### Discharge floor

In VictronConnect see: Setting > Battery > Discharge floor

This setting is used in "the time to go" calculation and is set at 50% by default for lead acid batteries. However, lithium batteries usually can be discharged significantly deeper than 50%. The discharge floor can be set to a value between 10 and 20%, unless the battery supplier advises otherwise.

#### Important warning

Lithium batteries are expensive and can be irreparably damaged due to very deep discharge or overcharge. Damage due to deep discharge can occur if small loads slowly discharge the battery when the system is not in use. Some examples of these loads are alarm systems, standby currents of DC loads and back current drain of battery chargers or charge regulators.

A residual discharge current is especially dangerous if the system has been discharged all the way until a low cell voltage shutdown has occurred. At this moment the state of charge can be as low as 1%. The lithium battery will get damaged if any remaining current is drawn from the battery. This damage can be irreversible.

A residual current of 1mA for example can damage a 100Ah battery if the battery has been left in discharged state during more than 40 days (1mA x 24h x 40 days = 0.96Ah).

The battery monitor draws <12mA from the battery. The positive supply must therefore be interrupted if a system with Li-ion batteries is left unattended during a period long enough for the battery monitor power consumption to completely discharge the battery.

In case of any doubt about possible residual current draw, isolate the battery by opening the battery switch, by pulling the battery fuse(s) or by disconnecting the battery positive when the system is not in use.

# 4.6. Configure for use as DC meter

In the VictronConnect battery monitor settings go to the "Misc" settings and select "DC energy meter" from the Monitor mode drop down menu. Once selected, you can choose what application the DC energy meter is used in.

# 5. Operation

# 5.1. How does the battery monitor work?

The main function of the battery monitor is to follow and indicate the state of charge of a battery, to be able to know how much charge the battery contains and to prevent an unexpected total discharge.

The battery monitor continuously measures the current flow in and out of the battery. Integration of this current over time, if it was a fixed current, boils down to multiplying current and time and gives the net amount of Ah added or removed.

For example: a discharge current of 10A for 2 hours will take 10 x 2 = 20Ah from the battery.

To complicate matters, the effective capacity of a battery depends on the rate of discharge, the Peukert efficiency, and, to a lesser extent, the temperature. And to make things even more complicated: when charging a battery more energy (Ah) has to be 'pumped' into the battery than can be retrieved during the next discharge. In other words: the charge efficiency is less than 100%. The battery monitor takes all these factors in consideration when calculating the state of charge.

#### 5.2. Readout overview

The VictronConnect app battery monitor status screen, display an overview of the most important parameters. These are:

- · State of charge.
- · Battery voltage.
- · Battery current.
- · Power.
- · Aux input reading (starter battery, midpoint or temperature).

#### State of charge

This is the actual state of charge of the battery in percentage and is compensated for both the Peukert efficiency and charge efficiency. The state of charge is the best way to monitor the battery.

A fully charged battery will be indicated by a value of 100.0%. A fully discharged battery will be indicated by a value of 0.0%.

Please note that if the state of charge indicates three dashes: "---" this means that the battery monitor is in an unsynchronised state. This mainly occurs when the battery monitor has just been installed or after the battery monitor has been left unpowered and is powered up again. For more information, see the Synchronising the battery monitor [15] chapter.

#### Voltage

This is the terminal voltage of the battery.

#### Current

This is the actual current flowing in or out of the battery. A negative current indicates that current is taken from the battery. This is the current needed for DC loads. A positive current means that current is going into the battery. This is current coming from charge sources. Keep in mind that the battery monitor will always indicate the total battery current, being the current traveling into the battery minus the current traveling out of the battery.

#### Power

The power drawn from or received by the battery.

#### **Consumed Ah**

The battery monitor keeps track of the Amp-hours removed from the battery compensated for the efficiency.

Example: If a current of 12A is drawn from a fully charged battery for a period of 3 hours, the readout will show -36.0Ah (-12 x 3 = -36).

Please note that if the Consumed Ah indicates three dashes: "---" this means that the battery monitor is in an unsynchronised state. This mainly occurs when the battery monitor has just been installed or after the battery monitor has been left unpowered and is powered up again. For more information, see the Synchronising the battery monitor [15] chapter.

#### Time remaining

The battery monitor estimates how long the battery can support the present load. This is the "time-to-go" readout and is the actual time left until the battery is discharged to the set "discharge floor". The discharge floor is by default set at 50%. For the discharge floor setting see the Discharge floor [20] chapter. If the load is fluctuating heavily, it is best not to rely on this reading too much,

as it is a momentary readout and should be used as a guideline only. We recommend the use of the state of charge readout for accurate battery monitoring.

If the "Time remaining" indicates three dashes: "---" this means that the battery monitor is in an unsynchronised state. This occurs when the battery monitor has just been installed or after it has been left unpowered and is powered up again. For more information, see see the Synchronising the battery monitor [15] chapter.

#### Input

This is the state of the Aux input. Depending on how the Aux port has been set up, you will see one of these options:

- · Starter battery voltage: This shows the voltage of a second battery.
- · Battery temperature: This shows the battery temperature of the main battery when the optional temperature sensor is used.
- Midpoint voltage deviation: This shows the deviation in a percentage of the main voltage of the battery bank top section compared to the voltage of the bottom section. For more information on this feature see the Midpoint voltage monitoring [30] chapter.

# 5.3. LED status codes

Both battery monitor LEDs are associated with the Bluetooth interface.

- On power-up, the blue LED will blink, and the red LED will quickly flash. The red LED will give a short flash to confirm that the
  red LED is functional.
- · When the blue LED is blinking, the Bluetooth interface is ready to be connected to the VictronConnect app.
- · When the blue LED stays on, the Bluetooth interface has successfully connected to VictronConnect app via Bluetooth.

See below table for an overview of all possible LED combinations of the Bluetooth module and their meaning.

Blue LED	RED LED	Operational state	Connection state	Description
Slow blinking	Off	VE.Direct gateway	Not connected	Ready for connection via Bluetooth
On	Off	VE.Direct gateway	Connected	Bluetooth successfully connected
On	On	VE.Direct gateway	Connected	VE.Direct communication problem
Slow blinking	Slow blinking	VE.Direct gateway	Not connected	VE.Direct communication problem
Double flash	Double flash	VE.Direct gateway	Not connected	Confirmation that the PIN code has been cleared
Fast blinking and alternating with red LED	Fast blinking and alternating with blue LED	Firmware update	Not connected	The firmware needs to be updated
On	Fast blinking	Firmware update	Connected	The firmware is being updated
On	Slow blinking	Firmware update	Programming	The firmware is being updated

# 5.4. Trends

The VictronConnect app provides battery monitor data logging. Providing that the firmware battery monitor is up to date, the battery monitor will store up to 45 days of past data and two of the following parameters can be viewed alongside:

- · Voltage (V).
- Current (A).
- Power (W).
- Consumed Amp Hours (Ah).
- State of charge (%).
- Temperature (°C).



VictronConnect battery monitor trends.

# 5.5. History

The battery monitor stores historic events. These can be used at a later date to evaluate usage patterns and battery health.

The history data is stored in a non-volatile memory and will not be lost when the power supply to the battery monitor has been interrupted or when the battery monitor has been reset to its defaults.

#### 5.5.1. Access history via VictronConnect

The history can be accessed in the "History" tab in VictronConnect.



VictronConnect battery monitor history screen.

#### 5.5.2. History data

#### Discharge information in Ah

- Deepest discharge: The battery monitor remembers the deepest discharge and each time the battery is discharged deeper the old value will be overwritten.
- Last discharge: The battery monitor keeps track of the discharge during the current cycle and displays the largest value recorded for Ah consumed since the last synchronisation.
- Average discharge: The cumulative Ah drawn divided by the total number of cycles.
- Cumulative Ah drawn: The cumulative number of Amp hours drawn from the battery over the lifetime of the battery monitor.

#### Energy in kWh

- · Discharged energy: This is the total amount of energy drawn from the battery in kWh.
- Charged energy: The total amount of energy absorbed by the battery in kWh.

#### Charge

• Total charge cycles: The number of charge cycles over the lifetime of the battery monitor. A charge cycle is counted every time the state of charge drops below 65% and then rises above 90%.

- Time since last full charge: The number of days since the last full charge.
- Synchronisations: The number of automatic synchronisations. A synchronisation is counted every time the state of charge drops below 90% before a synchronisation occurs.
- Number of full discharges: The number of full discharges. A full discharge is counted when the state of charge reaches 0%.

#### **Battery voltage**

- · Min battery voltage: The lowest battery voltage.
- · Max battery voltage: The highest battery voltage.
- Min starter voltage: The lowest auxiliary battery voltage (if applicable).
- Max starter voltage: The highest auxiliary battery voltage (if applicable).

#### Voltage alarms

- · Low voltage alarms: The number of low voltage alarms.
- · High voltage alarms: The number of high voltage alarms.

#### 5.6. Alarms

The battery monitor can raise an alarm on low state of charge, low or high battery voltages readings, low or high temperature readings or a certain midpoint deviation. The alarm will activate when the value reaches a set threshold and will deactivate when the value clears this threshold. The thresholds are configurable. For more information see the Alarm settings [23] chapter.

The alarm is a software alarm.

When connecting with the VictronConnect app and an alarm is active, the alarm will show in the app. Or, alternatively, when the battery monitor is connected to a GX device, the alarm will show up on the GX device display or on VRM portal.

In case of VictronConnect, an alarm is acknowledged when a button is pressed. And in a GX device an alarm is acknowledged when viewed in notifications. However, the alarm icon is displayed as long as the alarm condition remains.

Please note that unlike the BMV battery monitor range, the SmartShunt does not have an alarm relay or buzzer. In case a relay function is needed, connect it to a GX device and use the relay in the GX device for battery monitor alarm functionality.



Left: alarm displayed on the VictronConnect app. Right: alarm displayed on a GX device.

#### 5.7. Synchronising the battery monitor

For a reliable readout, the state of charge, as displayed by the battery monitor, must self-synchronise regularly with the true state of charge of the battery. This to prevent drift of the "State of charge" value over time. A synchronisation will reset the state of charge of the battery to 100%.

#### 5.7.1. Automatic synchronisation

Synchronisation is an automatic process and will occur when the battery has been fully charged. The battery monitor will look at a few parameters to ascertain that the battery has been fully charged. It will consider the battery to be fully charged when the voltage has reached a certain value and the current has dropped below a certain value for a certain amount of time.

These parameters are called:

- Charged voltage the float voltage of battery charger.
- · Tail current a percentage of the battery capacity.
- · Charged detection time the time in minutes.

As soon as these 3 parameters have been met, the battery monitor will set the state of charge value to 100%, thus synchronising the state of charge.

### Example:

In case of a 12V battery, the battery monitor will reset the battery's state of charge to 100% when all these parameters have been met:

- · The voltage exceeds 13.2V,
- the charge current is less than 4.0% of the total battery capacity (e.g. 8A for a 200Ah battery) and,
- 3 minutes have passed while both the voltage and current conditions are met.

If the battery monitor does not perform a regular synchronisation, the state of charge value will start to drift over time. This is due to the small inaccuracies of the battery monitor and because of the estimation of the Peukert exponent. Once a battery has been fully charged, and the charger has gone to float stage, the battery is full and the battery monitor will automatically synchronise by setting the state of charge value to 100%.

#### 5.7.2. Manual synchronisation

The battery monitor can be synchronised manually if required. This can be done by pressing the "Synchronise" button in VictronConnect. Navigate to "settings" and then to "battery settings".

A manual synchronisation can be needed in situations when the battery monitor does not synchronise automatically. This is for example needed on first install or after the voltage supply to the battery monitor has been interrupted.

A manual synchronisation can also be needed when the battery has not been fully charged, or if the battery monitor has not detected that the battery has been fully charged because the charged voltage, current or time have been set incorrectly. In this case review the settings and make sure the battery regularly receives a full charge.

### 5.8. Operation as a DC meter

The battery monitor can be set up as a DC energy meter. It is used to measure DC production or consumption of a specific device in a system, like for example an alternator, wind turbine or hydro generator. Or similarly, the consumption of a specific circuit or load in a DC system.

When in DC monitor mode, the voltage, current and power is displayed.



VictronConnect status screen of a battery monitor running in DC monitor mode.



Note that the wiring of a DC meter differs from battery monitor wiring, see the Wiring for use as DC meter [6] chapter how to wire. When switching between modes, it is recommended to reset all history data.

# 6. Interfacing


The battery monitor can be connected to other equipment, this chapter describes how this can be done.

### 6.1. VictronConnect via USB

VictronConnect can not only connect via Bluetooth but it can also connect via USB. A USB connection is essential when connecting to the Windows version of VictronConnect and is optional when the MacOS or Android version us used. Please note that in case of connecting to an Android phone or tablet a "USB on the Go" cable might be needed.

To connect via USB, you will need a VE.Direct to USB interface. Use this interface to connect the computer to the SmartShunt.

For more information see the VictronConnect manual.



Example of a VE.Direct to USB interface connection between the battery monitor and a computer.

#	Description	
Α	VE.Direct to USB interface	
В	Computer or laptop	

# 6.2. Connecting to a GX device and the VRM portal

GX devices are Victron devices that provide control and monitoring for all Victron equipment products connected to it. Control and monitoring can be done locally but can also be done remotely via our free remote monitoring website "Victron Remote Monitoring", the VRM online portal. For an overview of all available GX devices, see: https://www.victronenergy.com/panel-systems-remote-monitoring.


For a link to the VRM website, see: https://vrm.victronenergy.com.

The battery monitor can be connected to a GX device with a VE.Direct cable. The VE.Direct cables are available in lengths ranging from 0.3 to 10 meters and are available with straight or right-angle connectors. Instead of using a VE.Direct cable, the battery monitor can also connect to GX device using the VE.Direct to USB interface.

Once connected, the GX device can be used to read out all monitored battery parameters.



Battery monitor information displayed by a GX device.



Example of a battery monitor connecting to a GX device.

#	Description	
Α	VE.Direct cable	
В	GX device	
С	Local monitoring via WiFi or Ethernet	
D	Internet	
Е	Remote monitoring via the VRM portal	

# 6.3. Connecting to a VE.Smart network


The VE.Smart network is a wireless network which allows a number of Victron products to exchange information via Bluetooth. The battery monitor can share battery voltage and temperature (optional temperature sensor needed) via Bluetooth using a VE.Smart network.

For example: A VE.Smart network containing a battery monitor with temperature sensor and a solar charger. The solar charger receives the battery voltage and temperature information from the battery monitor and uses this information to optimise its charge parameters. This will improve charging efficiency and will prolong battery life.

To make the battery monitor part of a VE.Smart network, you will have to either create a network or join an existing network. The setting can be found in the VictronConnect app. Navigate to the battery monitor page and then to: settings > smart networking. Please see the VE.Smart network manual for more information.



Creating a VE.Smart network using the VictronConnect app.



Example of a system containing a battery monitor with temperature sensor and a solar charger, both using the VE.Smart network.

#	Description	
Α	Temperature sensor	
В	Solar charger	
С	VE.Smart network connection via Bluetooth	

# 6.4. Custom integration



Please note that this is an advanced feature and requires programming knowledge.

The VE.Direct communications port can be used to read data and change settings. The VE.Direct protocol is extremely simple to implement. Transmitting data to the battery monitor is not necessary for simple applications: the battery monitor automatically sends all readings every second.

All the details are explained in this document:

 $https://www.victronenergy.com/upload/documents/Technical-Information-Data-communication-with-Victron-Energy-products\_EN.pdf$ 

# 7. All features and settings

This chapter explains all battery monitor settings. In addition to this we also have a video available explaining these settings and how the interact with each other to achieve accurate battery monitoring for both lead acid and lithium batteries.

Link to the video:

https://www.youtube.com/embed/mEN15Z\_S4kE

# 7.1. Battery settings

These settings can be used to fine-tune the battery monitor. Please be careful when you change these settings as a change will have an effect on the battery monitor state of charge calculations.

### 7.1.1. Battery capacity

This parameter is used to tell the battery monitor how big the battery is. This setting should already have been done during the initial installation.

The setting is the battery capacity in Amp hours (Ah).

For more information on Battery capacity and Peukert exponent see chapter Battery capacity and Peukert exponent [28]

Default setting	Range	Step size
200 Ah	1 - 9999 Ah	1 Ah

### 7.1.2. Charged voltage

The battery voltage must be above this voltage level to consider the battery as fully charged. As soon as the battery monitor detects that the voltage of the battery has reached the "charged voltage" and the current has dropped below the "tail current" for a certain amount of time, the battery monitor will set the state of charge to 100%.

Default setting	Range	Step size
0 V	0V - 95V	0.1V

The "charged voltage" parameter should be set to 0.2V or 0.3V below the float voltage of the charger.

#### Table 1. Recommended settings for lead acid batteries:

Nominal battery voltage	Charged voltage setting
12V	13.2V
24V	26.4V
36V	39.6V
48V	52.8V

#### 7.1.3. Discharge floor

The "Discharge floor" parameter is used in the time remaining calculation. The battery monitor calculates the time it takes until the set "discharge floor" has been reached. It is also used to set the state of charge alarm defaults.

For lead-acid batteries set this to 50% and for lithium set it lower.

Default setting	Range	Step size
50%	0 - 99%	1%

#### 7.1.4. Tail current

The battery is considered as "fully charged" once the charge current has dropped to less than the set "Tail current" parameter. The "Tail current" parameter is expressed as a percentage of the battery capacity.

Remark: Some battery chargers stop charging when the current drops below a set threshold. In these cases, the tail current must be set higher than this threshold.

As soon as the battery monitor detects that the voltage of the battery has reached the set "Charged voltage" parameter and the current has dropped below the "Tail current" for a certain amount of time, the battery monitor will set the state of charge to 100%.

Default setting	Range	Step size
4.00%	0.50 - 10.00%	0.1%

#### 7.1.5. Charged detection time

This is the time the "Charged voltage" and "Tail current" must be met in order to consider the battery fully charged.

Default setting	Range	Step size
3 minutes	0 - 100 minutes	1 minute

#### 7.1.6. Peukert exponent

Set the Peukert exponent according the battery specification sheet. If the Peukert exponent is unknown, set it at 1.25 for lead-acid batteries and set it at 1.05 for lithium batteries. A value of 1.00 disables the Peukert compensation. The Peukert value for lead-acid batteries can be calculated. For more information on the Peukert calculation, battery capacity and Peukert exponent see the Peukert exponent chapter.

Default setting	Range	Step size	
1.25	1.00 - 1.50	0.01	

### 7.1.7. Charge efficiency factor

The "Charge Efficiency Factor" compensates for the capacity (Ah) losses during charging. A setting of 100% means that there are no losses.

A charge efficiency of 95% means that 10Ah must be transferred to the battery to get 9.5Ah actually stored in the battery. The charge efficiency of a battery depends on battery type, age and usage. The battery monitor takes this phenomenon into account with the charge efficiency factor.

Default setting	Range	Step size
95%	50 - 100%	1%

The charge efficiency of a lead acid battery is almost 100% as long as no gas generation takes place. Gassing means that part of the charge current is not transformed into chemical energy, which is stored in the plates of the battery, but is used to decompose water into oxygen and hydrogen gas (highly explosive!). The energy stored in the plates can be retrieved during the next discharge, whereas the energy used to decompose water is lost. Gassing can easily be observed in flooded batteries. Please note that the 'oxygen only' end of the charge phase of sealed (VRLA) gel and AGM batteries also results in a reduced charge efficiency.

#### 7.1.8. Current threshold

When the current measured falls below the "Current threshold" value it will be considered zero. The "Current threshold" is used to cancel out very small currents that can negatively affect the long-term state of charge readout in noisy environments. For example, if the actual long-term current is 0.0A and, due to injected noise or small offsets, the battery monitor measures 0.05A the battery monitor might, in the long term, incorrectly indicate that the battery is empty or will need to be recharged. When the current threshold in this example is set to 0.1A, the battery monitor calculates with 0.0A so that errors are eliminated.

A value of 0.0A disables this function.

Default setting	Range	Step size
0.10 A	0.00 - 2.00 A	0.01 A

#### 7.1.9. Time-to-go averaging period

The time-to-go averaging period specifies the time window (in minutes) that the moving averaging filter works. A value of 0 disables the filter and gives an instantaneous (real-time) readout. However, the displayed "Time remaining" value may fluctuate

heavily. Selecting the longest time, 12 minutes, will ensure that only long-term load fluctuations are included in the "Time remaining" calculations.

Default setting	Range	Step size
3 minutes	0 12 minutes	1 minute

#### 7.1.10. Battery starts synchronised

The battery state of charge will become 100% after the battery monitor is powered up. When ON, the battery monitor will consider itself synchronised when powered-up, resulting in a state of charge of 100%. If set to OFF, the battery monitor will consider it unsynchronised when powered-up, resulting in a state of charge that is unknown until the first actual synchronisation.

Default setting	Range
ON	ON/OFF

Please be aware that situations can occur where special consideration is needed when setting this feature to ON. One of these situations occurs in systems where the battery is often disconnected from the battery monitor, for example on a boat. If you leave the boat and disconnect the DC system via the main DC breaker and at that moment the batteries were, for example, 75% charged. On return to the boat the DC system is reconnected and the battery monitor will now indicate 100%. This will give a false impression that the batteries are full, while in reality they are partially discharged.

There are two ways of solving this, one is to not disconnect the battery monitor when the batteries are partially discharged or alternatively turn the "Battery starts synchronised" feature off. Now when the battery monitor is reconnected the state of charge will display "---" and will not show 100% until the batteries have been fully charged. Please note that leaving a lead acid battery in a partially discharged state for a length of time will cause battery damage.

#### 7.1.11. State of charge

With this setting you can manually set the state of charge value. This setting is only active after the battery monitor has, at least once, been synchronised. Either automatically or manually.

Default setting	Range	Step size	
%	0.0 - 100%	0.1%	

#### 7.1.12. Synchronise SoC to 100%


This option can be used to manually synchronise the battery monitor. Press the "Synchronise" button to synchronise the battery monitor to 100%.

For more information, see paragraph Manual synchronisation [16]

#### 7.1.13. Zero current calibration

This option can be used to calibrate the zero reading if the battery monitor reads a non-zero current even when there is no load and the battery is not being charged.

A zero current calibration is (almost) never needed. Only perform this procedure in case the battery monitor shows a current while you are absolutely sure that there is no actual current flowing. The only way to be sure of this, is to physically disconnect all wires and cables connected to the LOAD MINUS side of the shunt. Do this by unscrewing the shunt bolt and remove all cables and wires form that side of the shunt. The alternative, which is switching off loads or chargers, is NOT accurate enough as it does not eliminate small standby currents.



Performing a zero current calibration

# 7.2. Alarm settings


The SmartShunt is not equipped with a buzzer or an alarm relay like the BMV series is. The generated alarms are only visible on the VictronConnect app while connected to the SmartShunt or are used to send an alarm signal to a GX device.

#### 7.2.1. SoC alarm setting

When enabled, the alarm will activate when the state of charge falls below the set value for more than 10 seconds. The alarm will deactivate when the state of charge rises above the clear value

Default Setting	Range
Disabled	Disabled/enabled

When enabled	Default Setting		
Set value	1% 0 - 100% 1%		
Clear value	2%	0 - 100%	1%



# 7.2.2. Low voltage alarm

When enabled, the alarm will activate when battery voltage falls below the set value for more than 10 seconds. The alarm will deactivate when the battery voltage rises above the clear value.

Default setting	Range
Disabled	Disabled/Enabled

When enabled	Default setting		
Set value	1.0 V	0 - 95.0 V	0.1 V
Clear value	1.1 V	0 - 95.0 V	0.1 V

### 7.2.3. High voltage alarm

When enabled, the alarm will activate when battery voltage rises above the set value for more than 10 seconds. The alarm will deactivate when the battery voltage drops below the clear value.

Default setting	Range
Disabled	Disabled / Enabled

When enabled	Default setting		
Set value	1.1 V	0 - 95.0 V	0.1 V
Clear value	1.0 V	0 - 95.0 V	0.1 V

#### 7.2.4. Low starter voltage alarm

This setting is only available if the Aux input has been set to "Starter battery".

When enabled, the alarm will activate when starter battery voltage falls below the set value for more than 10 seconds. The alarm will deactivate when the starter battery voltage rises above the clear value.

Default setting	Range
Disabled	Disabled/Enabled

When enabled	Default setting		
Set value	1.0 V	0 - 95.0 V	0.1 V
Clear value	1.1 V	0 - 95.0 V	0.1 V

### 7.2.5. High starter voltage alarm

This setting is only available if the Aux input has been set to "Starter battery".

When enabled, the alarm will activate when starter battery voltage rises above the set value for more than 10 seconds. The alarm will deactivate when the starter battery voltage drops below the clear value.

Default setting	Range
Disabled	Disabled/Enabled

When enabled	Default setting		
Set value	1.1 V	0 - 95.0 V	0.1 V
Clear value	1.0 V	0 - 95.0 V	0.1 V

### 7.2.6. Midpoint deviation alarm

This setting is only available if the Aux input has been set to "Midpoint".

When enabled, the alarm will activate when the midpoint voltage deviation rises above the set value for more than 10 seconds. The alarm will deactivate when the midpoint voltage deviation drops below the clear value.

Default setting	Range
Disabled	Disabled/Enabled

When enabled	Default setting		
Set value	2 %	0 - 99 %	1 %
Clear value	1 %	0 - 99 %	1 %

# 7.2.7. High temperature alarm

This setting is only available if the Aux input has been set to "Temperature".

When enabled, the alarm will activate when the battery temperature rises above the set value for more than 10 seconds. The alarm will deactivate when the battery temperature drops below the clear value.

Default setting	Range
Disabled	Disabled/Enabled

When enabled	Default setting	Range	Step size
Set value	2°C (2°F)	-40 - +99°C (-40 - +210°F)	1°C (1°F)
Clear value	1°C (2°F)	-40 - +99°C (-40 - +210°F)	1°C (1°F)

#### 7.2.8. Low temperature alarm

This setting is only available if the Aux input has been set to "Temperature".

When enabled, the alarm will activate when the battery temperature falls below the set value for more than 10 seconds. The alarm will deactivate when the battery temperature rises above the clear value.

Default setting	Range
Disabled	Disabled/Enabled

When enabled	Default setting	Range	Step size
Set value	2°C (2°F)	-40 - +99°C (-40 - +210°F)	1°C (1°F)
Clear value	1°C (2°F)	-40 - +99°C (-40 - +210°F)	1°C (1°F)

# 7.3. Miscellaneous settings

#### 7.3.1. Monitor Mode

If you wish to use the battery monitor to monitor individual DC circuits, rather than as a whole-of-system battery monitor you can change the "Monitor mode" setting in the "Misc" menu from "Battery Monitor" to "DC Energy Meter".

If "DC meter" is selected, you can select the following types:

Solar charger, Wind charger, Shaft generator, Alternator, Fuel cell, Water generator, DC-DC charger, AC charger, Generic source, Generic load, Electric drive, Fridge, Water pump, Bilge pump, DC system, Inverter, Water heater.

When connected to a GX device, the type, and the current and the power is shown in the user interface and this information is also available on the VRM Portal.

When the GX device is also configured as type "has DC System", the GX does more than just recording and visualisation:

- The power shown in the DC system box is the sum of power reported by all battery monitors configured as such. Having
  multiple meters can be useful, for example in a catamaran, so that the DC systems in the port hull and in the starboard hull
  are being measured.
- The DC system current is being compensated for when setting DVCC charge current limits to inverter/chargers and solar chargers. For example, when a load of 50A is being measured, and CCL by the battery is 25A, the limit given to the inverter/ charger or solar charger is 75A.

See the GX device documentation for more information about these advanced features.

#### **7.3.2. Aux input**

This setting sets the function of the auxiliary input. Select between: None, Starter battery, Midpoint or Temperature

Default Setting	Range
None	None / Starter battery / Midpoint / Temperature

#### 7.3.3. Temperature coefficient

This setting is only available after the Aux input setting has been set to "Temperature".

The available battery capacity decreases with temperature. The temperature coefficient (delta T) is the percentage the battery capacity changes with temperature when temperature decreases to less than 20°C (above 20°C the influence of temperature on capacity is relatively low and is not taken into account). Typically, the reduction, compared to the capacity at 20°C, is 18% at 0°C and 40% at -20°C.

The unit of this value is "%cap/°C" or percent capacity per degree Celsius.

The typical value (below 20°C) is 1%cap/°C for lead acid batteries, and 0.5%cap/°C for LFP batteries.

Default setting	Range	Step size
0.0%cap/°C	0 - 2.0%cap/°C	0.1%cap/°C
0.0%cap/°F	0 - 3.6%cap/°F	0.1%cap/°F

# 7.4. Temperature unit setting

This setting can be found in the settings of the VictronConnect app itself. Leave the battery monitor page by clicking on the ← arrow. This will bring you back to the device list of the VictronConnect app. Click on the menu symbol and then click on the settings symbol. Here you can select the "Display temperature unit". Selecting Celsius will display the temperature in °C and selecting Fahrenheit will display the temperature in °F.

#### 7.5. Product settings

To access these settings, click on the settings symbol and then on the menu symbol

### 7.5.1. Reset to defaults

To set all settings back to default select "Reset to defaults". Please note that this only resets all settings to their default values, the history is not reset.

#### 7.5.2. Custom name

In the battery monitor product information screen, you can change the name of the battery monitor. By default, it is called by its product name. But a more applicable name might be needed, especially if you are using multiple battery monitors in close proximity of each other it might become confusing with which battery monitor you are communicating. You can, for example, add identification numbers to their name, like: Battery Monitor A, Battery Monitor B and so on.

#### 7.5.3. Firmware

Both the battery monitor and its Bluetooth interface run on firmware.

Occasionally a newer firmware version is available. New firmware is released to either add features or to fix a bug. The product overview of both the battery monitor and its Bluetooth interface items both display the firmware number. It also indicates whether the firmware is the latest version and there is a button you can press to update the firmware.

On first install it is always recommended to update to the most recent firmware (if available). Whenever you connect to the battery monitor with a "up to date" version of VictronConnect, it will check firmware and it will ask you to update firmware if there is a newer version available. VictronConnect includes the actual firmware files, so an internet connection is not needed to update to the most recent firmware, as long as you are using the most up to date version of VictronConnect.

A firmware update is not mandatory. If you choose not to update the firmware, you can only read out the battery monitor, but you cannot change settings. Settings can only be changed if the battery monitor runs on the most recent firmware.

#### 7.5.4. Changing PIN code

In the battery monitor Bluetooth interface product info the PIN code can be changed.

#### 7.5.5. Disabling and re-enabling Bluetooth

Bluetooth is enabled by default in the battery monitor. If Bluetooth is not wanted it can be disabled. This is done by sliding the Bluetooth switch in the product settings.

A reason to disable Bluetooth could be for security reasons, or to eliminate unwanted transmission from the Battery monitor.

As soon as Bluetooth has been disabled the only way to communicate with the battery monitor is via its VE.Direct port.

This is done via the USB to VE.Direct interface or via a GX device connected to the battery monitor via a VE.Direct cable or the USB to VE.Direct interface. For more info see chapter 6: "Interfacing".

Bluetooth can be re-enabled by connecting to the battery monitor with VictronConnect via the VE.Direct – USB interface. Once connected you can navigate to the product settings menu and re-enable Bluetooth.



VictronConnect product info screen.

#### 7.5.6. Serial number

The serial number can be found in the battery monitor product info section of the VictronConnect app or on the product information sticker on the battery monitor.

# 7.6. Saving, loading and sharing settings

In the settings menu you can find the following 3 symbols:

- Save settings to file This will save settings for reference or for later use.
- Load settings from file This will load earlier saved settings.
- ≺ Share settings file This allows you to share the settings file via email, message, airdrop and so on. The available sharing options depend on the platform used.

For more information on these features, see the VictronConnect manual.

# 7.7. Reset history

This setting can be found at to bottom of the history tab. Please be aware that history data is an important tool to keep track of battery performance and is also needed to diagnose possible battery problems. Do not clear the history unless the battery bank is replaced.

# 7.8. Reset PIN code

This setting can be found in the settings of the VictronConnect app itself. Leave the battery monitor by clicking on the ← arrow. This will bring you back to the device list of the VictronConnect app. Now, click on the menu symbol next to the battery monitor listing.

A new window will open which allows you to reset the PIN code back to its default: 000000. To be able to reset the PIN code you will need the enter the battery monitor unique PUK code. The PUK code is printed on the product information sticker on the Battery monitor.

# 8. Battery capacity and Peukert exponent

Battery capacity is expressed in Amp hour (Ah) and indicates how much current a battery can supply over time. For example, if a 100Ah battery is being discharged with a constant current of 5A, the battery will be totally discharged in 20 hours.

The rate at which a battery is being discharged is expressed as the C rating. The C rating indicates how many hours a battery with a given capacity will last. 1C is the 1h rate and means that the discharge current will discharge the entire battery in 1 hour. For a battery with a capacity of 100Ah, this equates to a discharge current of 100A. A 5C rate for this battery would be 500A for 12 minutes (1/5 hours), and a C5 rate would be 20A for 5 hours.



There are two ways of expressing the C rating of a battery. Either with a number before the C or with a number after the C.

For example:

- 5C is the same as C0.2
- · 1C is the same as C1
- 0.2C is the same as C5

The capacity of a battery depends on the rate of discharge. The faster the rate of discharge, the less capacity will be available. The relation between slow or fast discharge can be calculated by Peukert's law and is expressed by the Peukert exponent. Some battery chemistries suffer more from this phenomenon than others. Lead acid are more affected by this than lithium batteries are. The battery monitor takes this phenomenon into account with Peukert exponent.

#### Discharge rate example

A lead acid battery is rated at 100Ah at C20, this means that this battery can deliver a total current of 100A over 20 hours at a rate of 5A per hour. C20 = 100Ah (5 x 20 = 100).

When the same 100Ah battery is discharged completely in two hours, its capacity is greatly reduced. Because of the higher rate of discharge, it may only give C2 = 56Ah.

#### Peukert's formula

The value which can be adjusted in Peukert's formula is the exponent n: see the formula below.

In the battery monitor the Peukert exponent can be adjusted from 1.00 to 1.50. The higher the Peukert exponent the faster the effective capacity 'shrinks' with increasing discharge rate. An ideal (theoretical) battery has a Peukert exponent of 1.00 and has a fixed capacity regardless of the size of the discharge current. The default setting in the battery monitor for the Peukert exponent is 1.25. This is an acceptable average value for most lead acid batteries.

Peukert's equation is stated below:

 $Cp = I^n x t$  Where Peukert's exponent n is:

$$n = \frac{\log t2 - \log t1}{\log I1 - \log I2}$$

To calculate the Peukert exponent you will need two rated battery capacities. This is usually the 20h discharge rate and the 5h rate, but can also be the 10h and 5h, or the 20h and the 10h rate. Ideally use a low discharge rating together with a substantially higher rating. Battery capacity ratings can be found in the battery datasheet. If in doubt contact your battery supplier.



#### Calculation example using the 5h and the 20h rating

The C5 rating is 75Ah. The t1 rating is 5h and I1 is calculated:

$$I_1 = \frac{75Ah}{5h} = 15A$$

The C20 rating is 100Ah. The t2 rating is 20h and I2 is calculated:

$$I_2 = \frac{100Ah}{20h} = 5A$$

The Peukert exponent is:

$$n = \frac{\log 20 - \log 5}{\log 15 - \log 5} = 1.26$$

A Peukert calculator is available at http://www.victronenergy.com/ support-and-downloads/software#peukert-calculator



Please note that the Peukert exponent is no more than a rough approximation of reality, and that at very high currents, batteries will give even less capacity than predicted from a fixed exponent. We recommend not to change the default value in the battery monitor, except in case of lithium batteries.



# 9. Midpoint voltage monitoring

One bad cell or one bad battery can destroy a large, expensive battery bank.

A short circuit or high internal leakage current in one cell for example will result in undercharge of that cell and overcharge of the other cells. Similarly, one bad battery in a 24V or 48V bank of several series/parallel connected 12V batteries can destroy the whole bank.

Moreover, when new cells or batteries are connected in series, they should all have the same initial state of charge. Small differences will be ironed out during absorption or equalize charging, but large differences will result in damage during charging due to excessive gassing of the cells or batteries with the highest initial state of charge.


A timely alarm can be generated by monitoring the midpoint of the battery bank (i.e. by splitting the string voltage in half and comparing the two string voltage halves).


The midpoint deviation will be small when the battery bank is at rest, and will increase:

- At the end of the bulk phase during charging (the voltage of well charged cells will increase rapidly while lagging cells still need more charging).
- · When discharging the battery bank until the voltage of the weakest cells starts to decrease rapidly.
- · At high charge and discharge rates.

# 9.1. Battery bank and midpoint wiring diagrams


#### 9.1.1. Connecting and monitoring midpoint in a 24V battery bank






Due to the voltage drop over the positive and the negative cables the midpoint voltage is not identical.

In an unmonitored battery bank the midpoints should not be interconnected, one bad battery bank can go unnoticed and could damage all other batteries.







Always use busbars when applying midpoint voltage monitoring. The cables to the busbars must all have the same length.

Midpoints can only be connected if corrective action is taken in case of an alarm.





### 9.1.2. Connecting and monitoring midpoint in a 48V battery bank





Due to the voltage drop over the positive and the negative cables the midpoint voltage is not identical.





In an unmonitored battery bank the midpoints should not be interconnected, one bad battery bank can go unnoticed and could damage all other batteries.

Always use busbars when applying midpoint voltage monitoring. The cables to the busbars must all have the same length.

Midpoints can only be connected if corrective action is taken in case of an alarm.

# 9.2. Midpoint deviation calculation

The battery monitor measures the midpoint and then calculates the deviation in a percentage from what the midpoint should be.

$$\textit{Deviation} = \frac{100 \times (\textit{top string voltage - bottom string voltage})}{\textit{battery voltage}}$$

$$d = \frac{100 \times (Vt - Vb)}{V}$$


Where:

d is the deviation in %

Vt is the top string voltage

Vb is the bottom string voltage

V is the voltage of the battery (V = Vt + Vb)



# 9.3. Setting the alarm level

In case of VRLA (gel or AGM) batteries, gassing due to overcharging will dry out the electrolyte, increasing internal resistance and ultimately resulting in irreversible damage. Flat plate VRLA batteries start to lose water when the charge voltage approaches



15V (12V battery). Including a safety margin, the midpoint deviation should therefore remain below 2% during charging. When, for example, charging a 24V battery bank at 28.8V absorption voltage, a midpoint deviation of 2% would result in:

Therefore:

$$Vt = \frac{V \times d}{100} + Vb = \frac{V \times d}{100} + V - Vt = V \times \frac{1 + \frac{d}{100}}{2}$$

$$Vt = V \times \frac{1 + \frac{d}{100}}{2}$$
 and  $Vb = V \times \frac{1 - \frac{d}{100}}{2}$ 

$$Vt = 28.8 \times \frac{1 + \frac{2}{100}}{2} \approx 14.7$$
 and  $Vb = 28.8 \times \frac{1 - \frac{2}{100}}{2} \approx 14.1$ 

Obviously, a midpoint deviation of more than 2% will result in overcharging the top battery and undercharging the bottom battery. These are two good reasons to set the midpoint alarm level at not more than d = 2%.

This same percentage can be applied to a 12V battery bank with a 6V midpoint.

In case of a 48V battery bank consisting of 12V series connected batteries, the % influence of one battery on the midpoint is reduced by half. The midpoint alarm level can therefore be set at a lower level.

# 9.4. Alarm delay

In order to prevent the occurrence of alarms due to short term deviations that will not damage a battery, the deviation must exceed the set value during 5 minutes before the alarm is triggered. A deviation exceeding the set value by a factor of two or more will trigger the alarm after 10 seconds.

# 9.5. What to do in case of an alarm during charging

In case of a new battery bank the alarm is usually due to differences in the initial state of charge of the individual battery. If the deviation increases to more than 3% you should stop charging the battery bank and charge the individual batteries or cells separately. Another way is to substantially reduce the charge current to the battery bank, this will allow the batteries to equalize over time.

If the problem persists after several charge-discharge cycles do the following:

- In case of series/parallel connection disconnect the midpoint, parallel connection wiring and measure the individual midpoint
  voltages during absorption charging to isolate batteries or cells which need additional charging.
- · Charge and then test all batteries or cells individually.

In case of an older battery bank which has performed well in the past the problem may be due to systematic undercharge. In this case more frequent charging or an equalization charge is needed. Please note that only flooded deep cycle flat plate or OPzS batteries can be equalized. Better and regular charging will solve the problem.

In case there are one or more faulty cells:

- In case of series/parallel connection disconnect the midpoint, parallel connection wiring and measure the individual midpoint voltages during absorption charging to isolate batteries or cells which need additional charging.
- · Charge and then test all batteries or cells individually.

# 9.6. What to do in case of an alarm during discharging

The individual batteries or cells of a battery bank are not identical, and when fully discharging a battery bank, the voltage of some cells will start dropping earlier than others. The midpoint alarm will therefore nearly always trip at the end of a deep discharge.

If the midpoint alarm trips much earlier (and does not trip during charging), some batteries or cells may have lost capacity or may have developed a higher internal resistance than others. The battery bank may have reached the end of service life, or one or more cells or batteries have developed a fault:

• In case of series/parallel connection, disconnect the midpoint parallel connection wiring and measure the individual midpoint voltages during discharging to isolate faulty batteries or cells.



· Charge and then test all batteries or cells individually.

# 9.7. The Battery Balancer

A consideration can be made to add a Battery Balancer to the system. A Battery Balancer will equalize the state of charge of two series connected 12V batteries, or of several parallel strings of series connected batteries.

When the charge voltage of a 24V battery system increases to more than 27.3V, the Battery Balancer will turn on and compare the voltage over the two series connected batteries. The Battery Balancer will draw a current of up to 0.7A from the battery (or parallel connected batteries) with the highest voltage. The resulting charge current differential will ensure that all batteries will converge to the same state of charge. If needed, several balancers can be paralleled.

A 48V battery bank can be balanced with three Battery Balancers, one between each battery.

For more information see the Battery Balancer product page: https://www.victronenergy.com/batteries/battery-balancer



# 10. Troubleshooting

# 10.1. Functionality issues

#### 10.1.1. Unit is dead

On first connection the blue LED on the SmartShunt should be blinking.

If this is not the case check the fuse in the VBatt+ cable and also check the cable itself and its terminals.

Please note that the blue LED on the SmartShunt can also be off when Bluetooth has been disabled. The SmartShunt appears to be dead. See the Cannot connect via Bluetooth [34] chapter for instructions on how to fix this.

In case the temperature sensor is used:

- The temperature sensor M8 cable lug must be connected to the positive pole of the battery bank (the red wire of the sensor doubles as the power supply wire).
- · Check the fuse in the positive (red) cable.
- · Make sure the correct temperature sensor is used. Note that the MultiPlus temperature sensor is not suitable.
- Make sure the temperature sensor has been connected the right way. The red cable should connect the VBatt+ terminal and the black wire to the Aux terminal.

See the Auxiliary connection for temperature monitoring [6] chapter for connection instructions and a wiring diagram.

#### 10.1.2. Auxiliary port not working

Check the fuse in the Aux cable and also check the cable itself and its terminals.

In case the starter battery is being used: make sure that both battery banks have a common negative. See paragraph 3.4.1: "Aux connection for monitoring the voltage of a second battery" for connection instructions and a wiring diagram.

In case the temperature sensor is used:

- The temperature sensor M8 cable lug must be connected to the positive pole of the battery bank (the red wire of the sensor doubles as the power supply wire).
- Check the fuse in the positive (red) cable.
- · Make sure the correct temperature sensor is used. The MultiPlus temperature sensor does not work with the battery monitor.
- Make sure the temperature sensor has been connected the right way. The red cable should connect to the VBatt+ terminal and the black wire to the AuxAux terminal.

See the Auxiliary connection for temperature monitoring [6] chapter for connection instructions and a wiring diagram.

#### 10.1.3. Unable to change VictronConnect settings

Settings can only be changed if the battery monitor is running on the most up to date firmware. Update to the latest firmware with the VictronConnect app.

#### 10.2. Connection issues

#### 10.2.1. Cannot connect via Bluetooth

It is highly unlikely that the Bluetooth interface is faulty. Some pointers to try before seeking support:

- Is the battery monitor powered up? The blue light should be blinking. If not see the Unit is dead [34] chapter.
- Is another phone or tablet already connected to the battery monitor? This is indicated by a blue light that stays on. Only one phone or tablet can be connected the battery monior at any given time. Make sure no other devices are connected and try again.
- Is the VictronConnect app up to date?
- · Are you close enough to the battery monitor? In open space the maximum distance is about 20 meters.
- The shunt and the electric cables do negatively influence the range of the Bluetooth signal. The resulting range of 10-15 meter is however satisfactory in most cases. The proximity of other electrically conducting elements, such as the metal chassis of

a vehicle or seawater around the hull of a boat, may reduce the range of the Bluetooth signal to an unacceptable level. The solution in such a case is to add a VE.Direct Bluetooth Dongle (ASS030536011) to the system, and to switch off Bluetooth in the SmartShunt.

- Are you using the Windows version of the VictronConnect app? This version cannot do Bluetooth. Use Android, iOS or MacOS instead (or use the USB VE.Direct interface).
- · Has Bluetooth been turned off in the settings? See the Disabling and re-enabling Bluetooth [26] chapter

For connection issues, see the troubleshooting section of the VictronConnect manual: https://www.victronenergy.com/live/victronconnect:start

#### 10.2.2. PIN code lost

If you have lost the PIN code you will need to reset the PIN code to its default PIN code, see the Reset PIN code [27] chapter.

More information and specific instructions can be found in the VictronConnect manual: https://www.victronenergy.com/live/victronconnect:start


# 10.3. Incorrect readings

#### 10.3.1. Charge and discharge current are inverted

The charge current should be shown as a positive value. For example: 1.45A.

The discharge current should be shown as a negative value. For example: -1.45A.

If the charge and discharge currents are reversed, the negative power cables on the battery monitor must be swapped.




# 10.3.2. Incomplete current reading

The negatives of all the loads and the charge sources in the system must be connected to the system minus side of the shunt.

If the negative of a load or a charge source is connected directly to the negative battery terminal or the "battery minus" side on the shunt, their current will not flow through the battery monitor and will be excluded from the overall current reading and the state of charge reading.

The battery monitor will display a higher state of charge than the actual state of charge of the battery.



### 10.3.3. There is a current reading while no current flows

If there is a current reading while no current is flowing through the battery monitor, perform a zero current calibration [22] while all loads are turned off or set the current threshold [21].

#### 10.3.4. Incorrect state of charge reading

An incorrect state of charge can be caused by a variety of reasons.

#### Incorrect battery settings

The following parameter(s) will have an effect on the state of charge calculations if they have been set up incorrectly:

· Battery capacity

#### Incorrect state of charge due to a synchronisation issue:

The state of charge is a calculated value and will need to be reset (synchronised) every now and then.

The synchronisation process is automatic and is performed each time the battery is fully charged. The battery monitor determines that battery is fully charged when all 3 "charged" conditions have been met. The "charged" conditions are:

- · Charged voltage (Voltage)
- · Tail current (% of battery capacity)
- · Charge detection time (minutes)

Practical example of the conditions that need to be met before a synchronisation will take place:

- · The battery voltage has to be above 13.8V
- The charge current has to be less than 0.04 x battery capacity (Ah). For a 200Ah battery this is 0.04 x 200 = 8A
- · Both above conditions have to be stable for 3 minutes

If the battery is not fully charged or if the automatic synchronisation does not happen, the state of charge value will start to drift and will eventually not represent the actual state of charge of the battery.

The following parameter(s) will have an effect on automatic synchronisation if they have been set incorrectly:

- · Charged voltage
- · Tail current
- · Charged detection time
- · Not occasionally fully charging the battery

For more information on these parameters see the chapter: "Battery settings".

#### Incorrect state of charge due to incorrect current reading:

The state of charge is calculated by looking at how much current flows in and out of the battery. If the current reading is incorrect, the state of charge will also be incorrect. See paragraph Incomplete current reading [35]

#### 10.3.5. State of charge is missing

This means that the battery monitor is in an unsynchronised state. This can occur when the battery monitor has just been installed or after it has been unpowered for some time and is being powered up again.

To fix this, fully charge the battery. Once the battery is close to a full charge, the battery monitor should synchronise automatically. If that doesn't work, review the synchronisation settings.

If you know the battery is fully charged but don't want to wait until the battery synchronises, then perform a manual synchronisation, see paragraph Synchronise SoC to 100% [22].

#### 10.3.6. State of charge does not reach 100%

The battery monitor will automatically synchronise and reset the state of charge to 100% as soon as the battery has been fully charged. In case the battery monitor does not reach a 100% sate of charge, do the following:

- Fully charge the battery and check if the battery monitor correctly detects if the battery is fully charged.
- If the battery monitor does not detect that the battery has been fully charged you will need to check or adjust the charged voltage, tail current and/or charged time settings. For more information see Automatic synchronisation [15].

#### 10.3.7. State of charge always shows 100%

One reason could be that the negative cables going in and out of the battery monitor have been wired the wrong way around, see Charge and discharge current are inverted [35].

### 10.3.8. State of charge does not increase fast enough or too fast when charging

This can happen when the battery monitor thinks the battery is bigger or smaller than in reality. Check if the battery capacity [9] has been set correctly.

#### 10.3.9. Incorrect battery voltage reading

Issue with the VBatt+ cable, perhaps the fuse, the cable itself or one of the terminals are faulty or have loose connections.

Incorrect wiring: the VBatt+ cable has to be connected to the positive of the battery bank, not midway of the battery bank.

In case a temperature sensor is used, make sure the sensor is connected to the positive terminal of battery bank, not midway of the battery bank.

#### 10.3.10. Incorrect starter battery voltage reading

Starter battery voltage too low:

· Issue with the Aux cable, perhaps the fuse, the cable itself or one of the terminals are faulty or have loose connections.

Starter battery voltage missing:

 Make sure that both batteries share a common negative. For instructions on how to correctly wire the starter battery see Aux connection for monitoring the voltage of a second battery [5].

#### 10.3.11. Synchronisation issues

If the battery monitor does not synchronise automatically, one possibility could be that the battery never reaches a fully charged state. Fully charge the battery and see if the state of charge eventually indicates 100%.

Another possibility is that the charged voltage setting should be lowered and/or the tail current setting should be increased.

It is also possible that the battery monitor synchronises too early. This can happen in solar systems or in systems that have fluctuating charge currents. If this is the case change the following settings:

- Increase the "charged" voltage to slightly below the absorption charge voltage. For example: 14.2V in case of 14.4V absorption voltage (for a 12V battery).
- Increase the "charged detection time" and/or decrease the tail current to prevent an early reset due to passing clouds.

# 11. Technical data

# 11.1. Technical data


SmartShunt IP65	500A	
Supply voltage range	6.5 - 70 Vdc	
Current draw	< 1mA	
Input voltage range, auxiliary battery	6.5 - 70 Vdc	
Battery capacity (Ah)	1 - 9999 Ah	
Operating temperature range	-40 +50°C (-40 - 120°F)	
Auxiliary input	Measures voltage of second battery, temperature* or midpoint	
Temperature measurement range*	-20 +50°C	
VE.Direct communication port	Yes	
RESOLUTION & ACCURACY		
Current	± 0.01A	
Voltage	± 0.01V	
Amp hours	± 0.1Ah	
State of charge (0 - 100%)	± 0.1%	
Time-to-go	± 1 min	
Temperature (0 - 50°C or 30 - 120°F)*	± 1°C/°F	
Accuracy of current measurement	± 0.4%	
Offset	Less than 10 / 20 / 40 mA	
Accuracy of voltage measurement	± 0.3%	
INSTALLATION & DIMENSIONS		
	500A: 46 x 120 x 54 mm	
Dimensions (h x w x d)	1000A: 68 x 168 x 75 mm	
	2000A: 68 x 168 x 100 mm	
Shunt connection bolts	M10 (0.3937 inch)	
Protection category	IP65 (potted)	
STANDARDS		
Safety	EN 60335-1	
Emission / Immunity	EN-IEC 61000-6-1 / EN-IEC 61000-6-2 / EN-IEC 61000-6-3	
Automotive	EN 50498	
Vbatt cable	1.5m red cable, with 1A slow blow fuse and M10 eye terminal	
Aux cable	1.5m red cable, with 1A slow blow fuse and M10 eye terminal	
VE.Direct cable **	1.5 black cable, with VE.Direct socket	
Temperature sensor	Optional (ASS000100000)	
A note regarding the range of the Bluetooth signal	The shunt and the electric cables do negatively influence the range of the Bluetooth signal. The resulting range of 10-15 meter is however satisfactory in most cases. The proximity of other electrically conducting elements, such as the metal chassis of a vehicle or seawater around the hull of a boat, may reduce the range of the Bluetooth signal to an unacceptable level.	
	The solution in such a case is to add a VE.Direct Bluetooth Dongle (ASS030536011) to the system, and to switch off Bluetooth in the SmartShunt.	

 $<sup>^{\</sup>star}$  Only when optional temperature sensor is connected, temperature sensor is not included


\*\* The very first production batch (50 pcs) has a 30 cm VE.Direct cable.

# 12. Appendix

# 12.1. Dimensions SmartShunt IP65 500A



# 12.2. Dimensions SmartShunt IP65 1000A



# 12.3. Dimensions SmartShunt IP65 2000A

